

STOP CORONA

WEAR MASK

MAINTAIN SOCIAL DISTANCE



**DELHI JAL BOARD: GNCTD
CENTRAL LABORATORY WTP WAZIRABAD, DELHI-54**



THIS REPORT PERTAINS TO THE
PARTICULAR SAMPLE ONLY

TEST REPORT

Sample ID	Ref.No. D.J.B/DTQC/Wzd./2022/Paid-72-73		
Location /Address of Sample	Sachdeva Convent School, Wazirabad, Jagatpur Road, Street No.5, Sangam Vihar, Delhi-110084		
Name of Work	--		
Reference No.	--	Ref. Letter Date	28.06.2022
Challan No.	111	Challan Date	28.06.2022
Sample Collection date	29.06.2022	Analysis date	29.06.2022
Any other Information	--	Reporting date	04.07.2022

TEST RESULTS

S.N.	Parameters	Unit	As per the IS 10500		Inlet	Outlet
			Desirable limit	Permissible limit		
1	Turbidity	NTU	1	5	1.73	1.62
2	pH Value	--	6.5-8.5	No relaxation	7.43	7.21
3	Colour	Pt-Co	5	15	Clear	Clear
4	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
5	Electrical Conductivity	µs/cm	-	-	131	120
6	Total Dissolved Solids	Mg/l	500	2000	66	60
7	Total Alkalinity as CaCO ₃	Mg/l	200	600	46	42
8	Total Hardness as CaCO ₃	Mg/l	200	600	68	64
9	Calcium as Ca	Mg/l	75	200	20	19.2
10	Magnesium as Mg	Mg/l	30	100	4.32	3.84
11	Ammonical-Nitrogen	Mg/l	NIL	0.5	ND	ND
12	Nitrate	Mg/l	--	45	3.21	3.29
13	Chlorides as Cl	Mg/l	250	1000	16	14
14	Fluoride as F	Mg/l	1.0	1.5	0.27	0.23
15	Sulphate as SO ₄	Mg/l	200	400	18.4	17.7
16	T. Iron	Mg/l	--	1.0	0.06	0.04
17	Residual Chlorine	Mg/l	0.2	1.0	1.5	1.25
18	COLIFORM COUNT AT 37° C	MPN/100 ml	Absent	--	0	0

.....End of Report.....

Remarks : On the basis of above tested parameters, above water samples conform drinking Water Specification IS-10500 & can be considered fit for drinking purpose.

ACWA

Asst. Chief Water Analyst
Delhi Jal Board, WTP Wazirabad

CHEMIST

A/CHEMIST





NORTH DELHI MUNICIPAL CORPORATION

(Office of Dy. Health Officer: Civil Lines Zone)

Public Health Department

16 RAJ PUR ROAD, DELHI - 110054

Email: dhocivillineszone162018@gmail.com Tel: 011-23985804



No: - DHO/CLZ/2022/2195

Dated: - 16/12/22

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Sh. Suresh Chandra (Asst. Public Health Inspector/CLZ) from Public Health Department Civil Lines Zone inspected the **SACHDEVA CONVENT SCHOOL** Situated at Wazirabad, Jagatpur Road, Street No.-5, Sangam Vihar, Delhi-110084 on dated 14.12.2022 and found that the **SACHDEVA CONVENT SCHOOL** has safe drinking water facilities for the students and member of staff of the institution and is maintaining the hygiene & sanitation condition in the school building & the campus. This certificate is valid for one year from date of issue.


Deputy Health Officer
Civil Lines Zone
16, Rajpur Road, Delhi-110054
North Delhi Municipal Corporation

Principal
SACHDEVA CONVENT SCHOOL
Wazirabad, Jagatpur Road, Street No.-5,
Sangam Vihar, Delhi-110084