



DELHI JAL BOARD: GNCTD
CENTRAL LABORATORY WTP WAZIRABAD, DELHI-54



TEST REPORT

Sample ID	Ref.No. D.J.B/CWA/Wtd /2023-24/DJid-167-168		
Location /Address of Sample	Sachdeva Convent School, Wazirabad, Jagatpur Road, Street No.5, Sangam Vihar, Delhi-110084		
Reference No.	Nil	Ref. Letter Date	16.11.2023
Challan No.	232	Challan Date	17.11.2023
Sample Collection date	20.11.2023	Analysis date	22.11.2023
Any other information	**	Reporting date	28.11.2023

TEST RESULTS

S.No.	Parameters	Unit	As per the IS 10500		Inlet	Outlet
			Desirable limit	Permissible limit		
1	Turbidity	NTU	1	5	1.2	1.1
2	pH Value	--	6.5-8.5	No relaxation	7.23	7.24
3	Colour	Pt-Co	5	15	1.0	1.0
4	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
5	Electrical Conductivity	µS/cm	-	-	112	96
6	Total Dissolved Solids	mg/L	500	2000	73	62
7	Total Alkalinity as CaCO ₃	mg/L	200	600	32	16
8	Total Hardness as CaCO ₃	mg/L	200	600	20	16
9	Calcium as Ca	mg/L	75	200	5.0	4.0
10	Magnesium as Mg	mg/L	30	100	2.0	1.4
11	Ammonical-Nitrogen	mg/L	NIL	0.5	BDL	BDL
12	Nitrate	mg/L	-	45	1.8	1.6
13	Chlorides as Cl	mg/L	250	1000	14	10
14	Fluoride as F	mg/L	1.0	1.5	0.36	0.28
15	Sulphate as SO ₄	mg/L	200	400	3.9	3.1
16	T. Iron	mg/L	-	1.0	0.06	0.06
17	Residual Chlorine	mg/L	0.2	1.0	BDL	BDL
18	COLIFORM COUNT AT 37° C	MPN/100 mL	Absent	-	0	0

End of Report

Remarks: For the tested parameters, above water samples conform drinking Water Specification IS-10500 & fit for drinking purpose.

[Signature]
Tested by
Lab.Tech.

[Signature]
Verified by
Asstt. Chemist

[Signature]
Authorized Analyst
Chemist/Analyst
Lab. No. 11, WTP, Wazirabad

[Signature]
Principal
SACHDEVA CONVENT SCHOOL,
Wazirabad, Jagatpur Road,
Street No. 5, Sangam Vihar, Delhi-84



MUNICIPAL CORPORATION OF DELHI
(PUBLIC HEALTH DEPARTMENT: CIVIL LINES ZONE
16 RAJ PUR ROAD, DELHI - 110054)

DHO/CLZ/2024/119...

Dated: 19/4/24

SCHOOL HEALTH CERTIFICATE

NAME OF THE SCHOOL : M/S Sachdeva Convent School
at Sachdeva Convent School situated at Wazirabad, Jagat
Pur Road, Street No. 5, Sangam Vihar, Delhi 110084.

: No of Student : BOYS - 320, GIRLS- 238, TOTAL-558

: No of Staff Members : 25

: Date of Inspection : 18.04.2024

- Rooms are having properly white washed, ventilated and having adequate lighting.
- Drinking water: Delhi Jal Board-Water supply with RO fitted water coolers are installed at each floor for student.
- No of Class Rooms : 25
- No of Toilets : Boys- 8, Girls- 7, Staff-1 Total- 16

Sanitation & Hygiene : General sanitation and hygiene are properly maintained in the school and is satisfactory from Health point of view.

In view of the above submissions this health certificate is being issued in favor of the school by undersigned, after being fully satisfied and having **NO OBJECTION FROM HEALTH POINT OF VIEW.**

The above certificate is valid for one year from date of issue.

Dy. Health Officer

Civil Lines Zone
Deputy Health Officer
Civil Lines Zone
Municipal Corporation of Delhi
16, Rajpur Road, Delhi-110054

Principal
M/S Sachdeva Convent School
at Wazirabad, Jagat Pur Road, Street No. 5,
Sangam Vihar, Delhi 110084.

Principal
SACHDEVA CONVENT SCHOOL
Wazirabad, Jagatour Road,
Street No. 5, Sangam Vihar, Delhi-84

